

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

AN APPLICATION OF FARMDALE WATER DISTRICT)	
TO DEVIATE FROM THE REQUIREMENTS OF 807)	CASE NO.
KAR 5:066, SECTION 4(4), REGARDING WATER)	95-201
STORAGE)	

O R D E R

On May 1, 1995, the Farmdale Water District ("Farmdale") applied for a deviation from Commission regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. The Commission had previously ordered Farmdale to bring its water storage facility into compliance with Commission regulations by July 15, 1995.¹

In support of its application, Farmdale has submitted evidence that the Frankfort Electric and Water Plant Board ("Frankfort Plant Board") will provide from its own 500,000-gallon storage tank Farmdale's required storage until July 10, 2000. This tank is near to Farmdale's master meter. All water is fed to the master meter by gravity.

The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

¹ Case No. 90-339, The Application by Farmdale Water District to Deviate From the Requirements of 807 KAR 5:066, Section 5(4), Regarding Water Storage (Jan. 4, 1991).

1. The total water storage capacity of Farmdale is approximately 378,000 gallons.

2. Farmdale's average consumption for the year 1994 was approximately 531,000 gallons per day.

3. The Frankfort Plant Board is willing to provide Farmdale with the additional needed storage capacity for five years until July 10, 2000.

IT IS THEREFORE ORDERED that:


1. Farmdale be and it hereby is granted a deviation until July 10, 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).


2. Farmdale shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to July 10, 2000.

Done at Frankfort, Kentucky, this 5th day of June, 1995.


PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director